



NOTES:

- A. PRIOR TO BACKFILLING, THE CONTRACTOR SHALL VACUUM TEST ALL MANHOLES TO ENSURE NO LEAKAGE WILL OCCUR. SEE REQUIREMENTS IN CITY SPECIAL PROVISIONS.
- B. THE CITY MAY REQUIRE THE CONTRACTOR TO HYDROFLUSH THE SEWER LINES IF ANY CONSTRUCTION DEBRIS IS FOUND IN THE LINES.
- C. SEE DETAIL SS1 FOR INSIDE DROP INFORMATION.

**ALL JOINTS & PICK POINTS
SHALL BE SEALED WITH
RAM-NEK OR A SIMILAR
PRODUCT APPROVED BY THE
CITY.**

**SANITARY SEWER
SPECIAL MANHOLE**
(FOR PIPES 30"Ø AND GREATER)

DATE	REVISIONS	BY

CITY OF YUBA CITY	
STANDARD DETAIL	
SS6	
<i>[Signature]</i>	7/21/09
APPROVED	DATE