



NOTES:

1. INSIDE DIAMETER OF PIPE TO BE THE SAME AS THE PIPE TO WHICH IT CONNECTS.
2. ALTERATIONS OF SEWER GRADES WILL BE PERMITTED ONLY AFTER PERMISSION HAS BEEN RECEIVED FROM THE CITY ENGINEER.
3. WHENEVER THE SPAN OF THE PIPE EXCEEDS 5'-0" REPLACEMENT PROCEDURE AND MATERIAL SHALL BE AS DIRECTED BY THE CITY ENGINEER.
4. TRIM THE END OF THE EXISTING UTILITY TO REMAIN TO A CLEAN NEAT EDGE.
5. FOR SANITARY SEWER LINES USE EXTRA STRENGTH VITRIFIED CLAY PIPE OR PROTECTO 401 LINED DUCTILE IRON PIPE. FOR STORM DRAIN LINES USE CONCRETE PIPE OF THE SAME TYPE THAT WAS REMOVED.
6. BAND SEAL COUPLING SHALL HAVE STAINLESS STEEL SHEAR RING.
7. THE "CALIFORNIA WATERWORKS STANDARDS" SET FORTH THE MINIMUM SEPARATION REQUIREMENT FOR WATER MAINS WITH SANITARY SEWERS AND STORM SEWER LINES. THESE STANDARDS ARE CONTAINED IN SECTION 64572, TITLE 22, CALIFORNIA CODE OF REGULATIONS.

UTILITY CROSSING

DATE	REVISIONS	BY

CITY OF YUBA CITY	
STANDARD DETAIL	
TR6	
<i>[Signature]</i>	7/21/09
APPROVED	DATE