



NOTES:

1. EQUIPMENT TO BE INSTALLED A MIN. OF 24" FROM ANY STRUCTURE OR HARDCAPING.
2. WHEN UNIT IS NEAR A STRUCTURE: MOUNT TEST COCK ON OPEN OR NON-OBSTRUCTED SIDE.
3. REFER TO SPECIFICATIONS & PLAN SHEET FOR MORE INFORMATION.
4. PROVIDE A LOCKABLE, EXPANDED METAL & INSULATED PROTECTIVE ENCLOSURE. USE PLACER WATER WORKS MODEL #PW/E1AW OR CITY APPROVED EQUAL.
5. FOR ADDITIONAL INFORMATION SEE DETAIL W10.

BACKFLOW PREVENTER DETAIL

	REVISIONS	BY

CITY OF YUBA CITY
STANDARD DETAIL
W11
<i>[Signature]</i> 7/21/09
APPROVED DATE