



NOTES:

1. THE CITY WILL INSTALL THE DOMESTIC/LANDSCAPE WATER SERVICE FROM THE WATER MAIN TO THE METER.
2. THE CITY WILL DO THE HOT TAP AND SET A GATE VALVE FOR THE FIRE SERVICE. THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING THE FIRE SERVICE FROM THE GATE VALVE TO THE BUILDING.
3. ALL DOMESTIC, LANDSCAPE, AND FIRE SERVICES SHALL HAVE REDUCED PRESSURE BACKFLOW PREVENTERS (THIS EXCLUDES SINGLE FAMILY DWELLINGS AND DUPLEXES).
4. SEE CITY STANDARD DETAILS W10 & W17 FOR ADDITIONAL BACKFLOW PREVENTER INFORMATION.

BACKFLOW PREVENTER SCHEMATIC

4/21/16	UPDATED NOTE 4	SAL
DATE	REVISIONS	BY

CITY OF YUBA CITY	
STANDARD DETAIL	
W19	
<i>Diana Langley</i> APPROVED	<i>4/22/16</i> DATE