



NOTES:

- 1" SERVICES SHALL BE COPPER TYPE "K" SOFT.
- SPLICES IN THE SERVICE LINE ARE TO BE AVOIDED; BUT WHERE APPROVED, THEY SHALL BE MADE USING CTS GRIP-TYPE COMPRESSION COUPLINGS.
- ALL FITTINGS ARE COPPER OR BRASS AND SHALL BE MUELLER 110 (CONDUCTIVE TYPE) COMPRESSION CONNECTIONS OR CITY APPROVED EQUAL.
- WHEN BACKFLOW PREVENTER IS REQUIRED, SEE DETAIL W10.
- ROCK BOTTOM OF BOX WITH 3" MIN. OF 3/4" MINUS CRUSHED ROCK.
- PACK JOINT FITTINGS ARE NOT ACCEPTABLE.
- ALL MATERIALS SHALL COMPLY WITH ASSEMBLY BILL 1953 (LEAD FREE LAW)
- NO ABOVE GROUND STRUCTURE SHALL BE PLACED WITH IN 3 FEET OF THE WATER METER

CHRISTY		
CONDITION	MODEL NO.	LID TYPE
LAWN/LANDSCAPE	B-36	FIBERLITE-36 w/PROBE HOLE
CONCRETE	APPROVED ON A CASE-BY-CASE BASIS	

1" DUAL WATER SERVICE

11/17/11	lead free law	sal
4/21/16	changed meter to cellular read; added note 8	sal
DATE	REVISIONS	BY

CITY OF YUBA CITY	
STANDARD DETAIL	
W20	
<i>Diana Langley</i>	4/22/16
APPROVED	DATE