


	"X" LENGTH		
ROLL	6" CURB	8" CURB	10.4"
	4.5'	6.7'	10.4'

NOTE:

1. CONCRETE TO MEET MIN 2500 PSI WITH MAX SLUMP OF 4" OR MEET CALTRANS REQUIREMENTS IN THE STANDARD SPECIFICATIONS SECTIONS 73 & 90.
2. MIN. LENGTH OF RESIDENTIAL D/W SHALL BE 12' & MAX. LENGTH 24'.
3. ALL CONCRETE REMOVALS SHALL BE TO NEAT SAW CUT LINES.
4. 95% RELATIVE COMPACTION REQUIRED ON SUBGRADE.
5. DRIVEWAY APPROACH SHALL BE POURED SEPARATELY FROM CURB UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER.
6. ON SITE GRADING MAY BE REQUIRED TO ELIMINATE EXCESSIVE GRADE CHANGE AND TO MAINTAIN SUITABLE DRAINAGE.
7. MAXIMUM CURB OPENING MAY BE INCREASED DUE TO SPECIAL CONDITIONS ON APPROVAL OF THE CITY ENGINEER.

STANDARD DRIVEWAY

DATE	REVISIONS	BY

CITY OF YUBA CITY
STANDARD DETAIL
ST10
 **APPROVED** **7/24/09** **DATE**