



- NOTES:**
- 1" SERVICES SHALL BE COPPER TYPE "K" SOFT.
 - SPLICES IN THE SERVICE LINE ARE TO BE AVOIDED; BUT WHERE APPROVED, THEY SHALL BE MADE USING CTS GRIP-TYPE COMPRESSION COUPLINGS.
 - ALL FITTINGS ARE COPPER OR BRASS AND SHALL BE MUELLER 110 (CONDUCTIVE TYPE) COMPRESSION CONNECTIONS OR CITY APPROVED EQUAL.
 - WHEN BACKFLOW PREVENTER IS REQUIRED, SEE DETAIL W10.
 - ROCK BOTTOM OF BOX WITH 3" MIN. OF 3/4" MINUS CRUSHED ROCK.
 - PACK JOINT FITTINGS ARE NOT ACCEPTABLE.

| CHRISTY | | |
|----------------|----------------------------------|---------------------------|
| CONDITION | MODEL NO. | LID TYPE |
| LAWN/LANDSCAPE | B-36 | FIBERLITE-36 w/PROBE HOLE |
| CONCRETE | APPROVED ON A CASE-BY-CASE BASIS | |

1" DUAL WATER SERVICE

| DATE | REVISIONS | BY |
|------|-----------|----|
| | | |
| | | |
| | | |

CITY OF YUBA CITY

STANDARD DETAIL

W20

[Signature] 12/3/10
 APPROVED DATE