



NOTES:

1. 1" SERVICES SHALL BE COPPER TYPE "K" SOFT.
2. SPLICES IN THE SERVICE LINE ARE TO BE AVOIDED; BUT WHERE APPROVED, THEY SHALL BE MADE USING CTS GRIP-TYPE COMPRESSION COUPLINGS.
3. ALL FITTINGS ARE COPPER OR BRASS AND SHALL BE MUELLER 110 (CONDUCTIVE TYPE) COMPRESSION CONNECTIONS OR CITY APPROVED EQUAL.
4. WHEN BACKFLOW PREVENTER IS REQUIRED, SEE DETAIL W10.
5. ROCK BOTTOM OF BOX WITH 3" MIN. OF 3/4" MINUS CRUSHED ROCK.
6. PACK JOINT FITTINGS ARE NOT ACCEPTABLE.



| CHRISTY | | |
|----------------|-----------|--------------------|
| CONDITION | MODEL NO. | LID TYPE |
| LAWN/LANDSCAPE | B-16 | FL16P BADGER ORION |

1" WATER SERVICE MAIN CONNECTION

| DATE | REVISIONS | BY |
|------|-----------|----|
| | | |
| | | |
| | | |

CITY OF YUBA CITY

STANDARD DETAIL

W6

[Signature] 7/21/09
 APPROVED DATE