



BLOWOFF HYDRANT
REFER TO DETAIL W9

BARRICADE
(SEE DETAIL ST19)

USE CHRISTY B1017-61JH LID OR
APPROVED EQUAL IF BOX IS IN PAVED
AREA. USE CHRISTY B-16D LID OR APPROVED
EQUAL IN UNPAVED AREA ONLY.

USE CHRISTY PRECAST BOX B1017BOX OR
APPROVED EQUAL IF BOX IS IN PAVED
AREA. USE CHRISTY PRECAST BOX B-16 OR
APPROVED EQUAL IN UNPAVED AREA ONLY.

LOCATING WIRE

2" MAX SEPARATION

2" TYPE "K" HARD COPPER

WATER MAIN

CONCRETE THRUST BLOCK

COUPLING WITH
TAPPED PLUG

RED BRASS NIPPLE

90° BRASS ELBOW. CTS FITTING
W/ COMPRESSION CONNECTION.

NOTE:
1. PACK JOINT FITTINGS ARE NOT ACCEPTABLE.

DEAD-END WATER MAIN

CITY OF YUBA CITY	
STANDARD DETAIL	
W8	
<i>[Signature]</i>	7/21/09
APPROVED	DATE

DATE	REVISIONS	BY